

Report Number	Event Title
---------------	-------------

Quarter: 2020Q1

N-2020-04266	Matter of Regulatory Interest: Ontario Power Generation Corporate Crisis Management and Communications Centre (CMCC) Activation
P-2019-07224	System Unavailable: Level 2 Impairment of Negative Pressure Containment System
P-2019-16932	System Unavailable: System Does Not Meet Design Intent of Steam Protection Door and H-Line Wall for Unit 8
P-2019-21963	Automatic Box-Up: Unit 4 Boxed-Up on High Activity while Venting Moderator Helium
P-2019-22113	Unplanned Change in Reactor Power: Unit 5 Setback As A Result of a Turbine Generator Trip Due To Boiler High Level
P-2020-00471	Safeguards: Temporary Loss of Power to Safeguards Equipment
P-2020-00480	Matter of Regulatory Interest: Provincial Emergency Operations Centre Emergency Alert Issued in Error by Province
P-2020-00556	Matter of Regulatory Interest: Pickering's Outfall A ECA Sample Morpholine Exceedance
P-2020-02730	Matter of Regulatory Interest: Grayloc Hub Seal Leak Discovered at Fuel Channel P-02 East
P-2020-03790	System Unavailable: System Does Not Meet Design Intent of Unit 6 Primary Heat Transport System
P-2020-04519	System Unavailable: System Does Not Meet Design Intent of ELPSW
P-2020-99999	Matter of Regulatory Interest: PNGS Site Employee Tested Positive for COVID-19

Quarter: 2020Q2

P-2020-06032	Matter of Regulatory Interest: Human Performance Event during Approach to Critical
P-2020-06140	Matter of Regulatory Interest: Fish Diversion Barrier Net not installed prior to Deadline in Fisheries Act Authorization due to Adverse Weather Conditions
P-2020-06264	Pressure Boundary Degradation: Relief Valve Failed to Lift during Post Testing
P-2020-06486	Matter of Regulatory Interest: Heat Transport System D2O Spill from East Fuel Machine
P-2020-06995	Pressure Boundary Degradation: Relief Valve Failed to Lift during Post Testing
P-2020-07205	Research Finding: Load Carrying Capacity Limiting for Tight Fitting Spacers (TFS) in Units 6, 7 and 8
P-2020-07566	System Unavailable: System Does Not Meet Design Intent of Unit 6 Auxiliary Boiler Feed System
P-2020-08231	System Unavailable: System Does Not Meet Design Intent of a Unit 1 Main Control Room Uninhabitable (MCRU) Credited Component
P-2020-08304	Unplanned Change in Reactor Power: Unit 1 Manual Setback Due to Governor Valve Oscillations

Quarter: 2020Q3

P-2020-08321	Annulus Gas Dewpoint Probes Unavailable on Unit 1
P-2020-08360	Automatic Box-Up: Unit 1 Boxed-up on High Activity
P-2020-08778	Pickering 058 Intake and Outfall Temperature Difference Exceeded the ECA Limit
P-2020-08840	Apparent Licence Condition Non-compliance: Emergency Response Maintainer Under Minimum Shift Complement
P-2020-08863	Apparent Licence Condition Non-compliance: PN 1-4 ANO Under Minimum Shift Complement
P-2020-08947	Matter of Regulatory Interest: Unexpected Unit 5 PT-CT Contact Core Assessment Results
P-2020-09150	Unplanned Change in Reactor Power: Unit 5 Manual Set Back During Turbine Test due to Governor Valve Oscillations
P-2020-10231	System Unavailable: System Does Not Meet Design Intent of Unit 1 Emergency Low Pressure Service Water
P-2020-10407	Radiation Hazard Sign Not Posted in Accordance with the Regulations
P-2020-11392	Unposted Hazard: Container with Radioactive Nuclear Substance Not Labelled in Accordance with Radiation Protection Regulations
P-2020-11415	Portion of Fire Suppression Piping found blocked by Corrosion Products and or Silt/Sand Build-up.
P-2020-11624	Unplanned Change in Reactor Power: Unit 7 Manual Setback Due to Governor Valve Failed Closed
P-2020-12535	System Unavailable: System Does Not Meet Design Intent of Unit 1 Primary Heat Transport System
P-2020-12634	System Unavailable: System Does Not Meet Design Intent of Unit 5 Auxiliary Boiler Feed System
P-2020-13137	System Unavailable: System Does Not Meet Design Intent of Unit 4 ELPSW and EHPSW

Quarter: 2020Q4

P-2019-17200	Action Level Exceedance : Gross Activity for Unit 018 Sewage Exceeded Monthly Action Level
P-2020-15012	Matter of Regulatory Interest: Potential Unplanned Intake of Alpha Contamination
P-2020-15049	Average Pickering 058 Discharge Temperature Difference to Lake Ontario Exceeded the ECA Limit
P-2020-15207	Pressure Boundary Degradation: Relief Valve Failed to Lift during Post Testing
P-2020-15956	System Unavailable: System Does Not Meet Design Intent of Unit 1 Emergency Low Pressure Service Water (ELPSW)
P-2020-16391	System Unavailable: System Does Not Meet Design Intent of Emergency Low Pressure Service Water (ELPSW)
P-2020-16423	Unplanned Change in Reactor Power: Unit 8 Setback Due to Governor Valve Oscillations
P-2020-16454	Pressure Boundary: Relief Valve Does Not Meet Design Specification
P-2020-16896	System Unavailable: System Does Not Meet Design Intent of Unit 4 Back-Up Instrument Air System
P-2020-17281	System Unavailable: System Does Not Meet Design Intent of Unit 1 Auxiliary Boiler Feed system
P-2020-17843	Matter of Regulatory Interest: Possible Workplace COVID-19 Transmission
P-2020-18627	Apparent Exceedance of 018 PNGS monthly Gross Beta/Gamma Environmental Action Limit
P-2020-18883	Matter of Regulatory Interest: Employee Tested Positive for COVID-19
P-2020-19375	Matter of Regulatory Interest: Employee Tested Positive for COVID-19